



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on February 27, 2007.

ENVIREAU TECHNOLOGIES INC.
320-3771 JACOMBS ROAD
RICHMOND, BRITISH COLUMBIA V6V 2L9
CANADA
604-270-2639

Facility: RICHMOND, BRITISH COLUMBIA, CANADA

Chemical/ Trade Designation	Function	Max Use
Copper Sulfate [CP]		
POLYDEX™	Algicide Bactericide	19 mg/L

[CP] The finished drinking water shall be monitored to ensure that levels of copper do not exceed 1.3 mg/L.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.